AUCKLAND LABORATORY
645 Great South Road Penrose, Auckland

Test Report

Client: McCallum Bros. Ltd
Address: 747 Rosebank Road, Avondale, Auckland

Laboratory No: A26/4969
Replacement Report No: 156713
Report Date: 4/11/2026

This report supersedes and replaces Report No: 156710
This replacement report was issued because the ALD is changed

Sample Details

Client reference	Pauanui Roading	**Date sampled:**	03/11/2026 14:00
Job Location:	Pauanui	**Sampled by:**	Shayne Elstob
Material:	Grade 3 Sealing Chip	**Date of sample receipt**	03/11/2026
Material Source:	Wilco Yard Stockpile		
Material Details	NZTA M06 _2019		
Sampling method	*Unknown sampling method		

Sample Notes

Sample acceptable for testing

Test results apply to sample as received.

Method Description	Testing Standard	Date tested
Size and shape of aggregate particles	NZS 4407:2015 Test 3.13	04/11/2026

	Results	*Specifications*
Passing 4.75mm sieve (%)	1.3	1.1 max
Number of particles tested	100	100 min
AGD/ALD Ratio	**2.07**	2.25 max
Within 2.5mm of ALD (%)	**77**	70 min
ALD (mm)	**8.70**	7.50 - 10.00

Frank Hu
Key Technical Personnel
Laboratory Section Head
IANZ Accreditation No: 240



Tests indicated as not accredited are outside the scope of the laboratory's accreditation.
This report may not be reproduced except in full.