AUCKLAND LABORATORY

645 Great South Road Penrose, Auckland

Test Report

Client: McCallum Bros. Ltd
Address: 747 Rosebank Road, Avondale, Auckland

Laboratory No: A26/4753
Replacement Report No: 156703
Report Date: 4/11/2026

This report supersedes and replaces Report No: 155972
This replacement report was issued because size and shape is removed

Sample Details

Client reference	Quality Assurance	**Date sampled:**	19/10/2026 06:00
Job Location:	Wilco Yard	**Sampled by:**	Shayne Elstob
Material:	Grade 4	**Date of sample receipt**	22/10/2026
Material Source:	Wilco Yard Stockpile		
Sampling method	*Unknown sampling method		


Sample Notes

Sample acceptable for testing

Test results apply to sample as received.

Method Description	Testing Standard	Date tested
Particle size distribution - Subsidiary method by dry sieving	NZS 4407:2015 Test 3.8.2	27/10/2026

Sieve Size	% Passing	Specification
13.2mm	100	
9.5mm	14	
6.7mm	1	
4.75mm	1	
2.36mm	1	
1.18mm	0	



Note: *PSD results obtained from an oven dry test sample.*

Method Description	Testing Standard	Date tested
Cleanness value of coarse aggregate	NZS 4407:2015 Test 3.9	26/10/2026

	Results
Cleanness value	**87**

Frank Hu
Key Technical Personnel
Laboratory Section Head
IANZ Accreditation No: 240

ACCREDITED IANZ TESTING LABORATORY

Tests indicated as not accredited are outside the scope of the laboratory's accreditation.
This report may not be reproduced except in full.